

VOC Content Test Certificate

Wednesday 1st November 2023

Supplier: SILIKAL AUSTRALIA

Product name: Silikal RU321 Pigmented Waterproofing Membrane

Date Tested: October 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)


Test Method: ASTM D2369-10: 2015 Standard Test Method for Volatile Content of Coatings: Table 1 – Method E with 2.0% of BPO catalyst, Pot time of 10 minutes and Induction time of 24 hours in sealed containers before putting in oven.

Test Data:


| | |
|--|---|
| Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B | Silikal RU321 Pigmented Waterproofing Membrane |
| Water Proofing Membranes and Sealant Limit: 250 grams per Litre | 18 grams per Litre as VOC content per material |
| <i>We hereby certify that Silikal RU321 Pigmented Waterproofing Membrane is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia</i> | |



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD. BE (Chem. Eng.)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant

Issued date: 1/11/2023

Expiry date: 1/11/2028

P23090067