

# VOC Content Test Certificate

Wednesday 1<sup>st</sup> November 2023

Supplier: SILIKAL AUSTRALIA

Product name: Silikal RU380 Standard Primer

Date Tested: October 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D2369-10: 2015 Standard Test Method for Volatile Content of Coatings: Table 1 – Method E with 2.5% of BPO catalyst, Pot time of 10 minutes and Induction time of 24 hours in sealed containers before putting in oven.

Test Data:

<b>Specification</b> <b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3-13.1.1B</b> <b>Green Star Interiors V1.3-12.1.1B</b>	<b>Silikal RU380 Standard Primer</b>
<b>One and two pack performance coatings for floor:</b> <b>140 grams per Litre</b>	<b>35 grams per Litre as VOC content per material</b>
<i>We hereby certify that Silikal RU380 Standard Primer is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia</i>	

Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

Tuan Duong  
PhD. BE (Chem. Eng.)  
Senior Consultant

Travis Hale  
BSc (Biotechnology)  
Senior Consultant

Issued date: 1/11/2023

Expiry date: 1/11/2028

P23090067