

VOC Content Test Certificate

Wednesday 7th January 2026

Supplier: SILIKAL AUSTRALIA (568 Collins Street, MELBOURNE, VIC, 3000, Australia).

Product name: SILIKAL® R 17

Date Tested: December 2025 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D2369-10: 2015 Standard Test Method for Volatile Content of Coatings:
Table 1 – Method E with 0% of BPO catalyst, Pot time of 10 minutes and
Induction time of 24 hours in sealed containers before putting in oven.

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	SILIKAL® R 17
One and two pack performance coatings for floor: 140 grams per Litre	45 grams per Litre as VOC content per material
<i>We hereby certify that SILIKAL® R 17 is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia</i>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
PhD. BE (Chem. Eng.)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant

Issued date: 7/01/2026

Expiry date: 7/01/2031

P25120109